

**PLEASE Submit to Mission Tech Support**

**Fax to 770-685-7913 or email to [setupforms@123mc.com](mailto:setupforms@123mc.com) email**

**Unit will not be activated until MISSION receives this form and enters the data in our computers**

Customer (Acct.) Name:

Unit Serial Number:

Install Date:

## DIGITAL OPTION BOARD INPUT PROGRAMMING:

Digital Input Number	Input Type (Factory Default)	Is Relay Normally Open or Closed? Choose one for each input. (Default N/O)	Input Description, 40 Character Max.
9	- (Alarm Only)		
10	- (Alarm Only)		
11	- (Alarm Only)		
12	- (Alarm Only)		
13	- (Alarm Only)		
14	- (Alarm Only)		
15	- (Alarm Only)		
16	- (Alarm Only)		

Alarm Delay:

Inputs 9-16 are set for the factor for a 10 sec. debounce time (default). Input contacts must be opened or closed for this period before initiation of event. It can be changed through programming.

Installation Notes: