

FOR USFCS USE ONLY

* FULL SCALE	CALCULATED mA/V OUTPUT	ACTUAL mA OUTPUT	P.S.I. FEET	TRANSDUCER RAW VALUE
0	4/1			
25	8/2			
50	12/3			
75	16/4			
100	20/5			

EXCITATION

MODEL A300
 SERIAL NO. 504307-001
 PRESSURE PSI
 CALIBRATED RANGE 0-XX.XFT

INSPECTION CHECK


PHYSICAL
 ELECTRICAL
 CALIBRATED

INFORMATION PROVIDED BY CUSTOMER

OVER FLOW=



ZERO OFFSET=



SENSOR LOCATION
 A=




OR
 B=

FEET

OR

FEET



STD: 3-0200-24X3601	INTL. REF:	BAR = 1" AT PLOT SCALE	REV	DESCRIPTION	DATE	DN	CHD	APVD	EDN	DESIGNER	DATE	TITLE	CLIENT	PROJECT	CODE	ENGINE	SHEET	REV
			A	AS SUBMITTED	12/05	CME	CME	CME			12/05	A300 ELEVATED TANK LEVEL CALIBRATION TECHNICAL SPECIFICATION	BRIDGEVILLE, DE.	504307	000	E11	1 OF 1	A



USFilter	US FILTER CONTROL SYSTEMS WADSWORTH, MA PH. 851-766-2700
----------	--